

TA Grade Texas Low Emission Diesel Fuel Specifications

Product Property	Test Method	Origin		Deliveries ^{1/}
		Minimum	Maximum	
Gravity, °API	D287	33.0	39.0	
Distillation				
IBP	D86	Report		
10% Recovered, °F		340	420	
50% Recovered, °F		400	490	
90% Recovered, °F		540	640	
EP		610	690	
Copper Corrosion	D130		1	
Cetane				
(1) Cetane Number	D613	48.0		
OR (2) Cetane Index, procedure B	D4737	48.0		
Cetane Index ^{2/}	D976	48		
Flash Point, °F	D93	140		125
Stability				
(1) Thermal, % reflectance	D6468 (W)	75		
	D6468 (Y)	82		
Aging Period (Minutes)	D6468	90		
OR (2) Potential Color ^{3/} and	MPL P. Color		6	
Potential Gum, mg/100 ml ^{4/}	MPL P. Gum		50	
OR (3) Oxidation, mg/100 ml	D2274		2.5	
Carbon Residue on 10% Bottoms, %	D524		0.35	
Cloud Point, °F	D2500		^{5/}	
Pour Point, °F	D97		^{5/}	
Viscosity, cSt at 104 °F	D445	2.0	4.1	
Ash, wt %	D482		0.01	
Haze Rating ^{6/}	D4176		2	3
NACE Corrosion	TM0172	B+		
Sulfur, ppm ^{7/}	D2622		*10	
Total Aromatic Hydrocarbon, Vol%	D5186		10	
Polycyclic Aromatic Hydrocarbon, wt%	D5186		1.4	
Nitrogen, ppm	D4629		10	

- 1/ Delivered products meets all applicable requirements at time and place of delivery.
- 2/ ASTM D976 data is required for low sulfur fuel oils to demonstrate aromatics compliance per the EPA.
- 3/ The Potential Color will be determined by ASTM method D1500 on a filtered sample after a 16 hour induction period by ASTM method D525 modified. Contact Magellan QC to request a copy of this method.

TA Grade Texas Low Emission Diesel Fuel Specifications (continued)

4/ The Potential Gum will be determined by ASTM method D381 modified (Steam Jet Evaporation at 485 °F) after a 16 hour induction period by ASTM method D525 modified. Contact Magellan QC to request a copy of this method.

5/

<u>Month</u>	<u>Pour Point °F, max.</u>	<u>Cloud Point °F, max</u>
January	0	+14
February	0	+14
March	0	+14
April	+10	+20
May	+10	+20
June	+10	+20
July	+10	+20
August	0	+14
September	0	+14
October	0	+14
November	0	+14
December	0	+14

6/ Compliance with ASTM D4176 will be determined using Procedure 2 at 77 °F or tank temperature at the time of sampling, whichever is lower.

7/ All results provided must use an EPA qualified instrument.
 *Sulfur limit, 11 ppm for interconnecting pipelines.

Dyes: TC Grade shipments may not be dyed.